




ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

WW 75 SHR



55 °C

35 °C



A++

A++



53 dB



- dB

■ 40
■ **40**
■ 40
kW

■ 46
■ **46**
■ 46
kW



2015

811/2013

WW 75 SHR

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	176	230
P_{rated} [kW]	40	46
Q_{HE} [kWh/y]	21501	16404
SCOP [-]	4.39	5.75
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	A++	A++
η [%]	154	228
P_{rated} [kW]	40	46
Q_{HE} [kWh/y]	29450	19834
SCOP [-]	3.85	5.71
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	A++	A++
η [%]	228	228
P_{rated} [kW]	40	46
Q_{HE} [kWh/y]	10635	10608
SCOP [-]	5.70	5.71
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓