



**ENERG** Y IJA  
енергия - ενεργεια IE IA

WW 07







55 °C

**A++**

35 °C

**A++**






**43** dB


■ 6    ■ 7

■ **6**    ■ **7**

■ 6    ■ 7

kW    kW







- dB

2015

811/2013

WW 07		ErP Data	
		55 °C	35 °C
Energy class		<b>A++</b>	<b>A++</b>
$\eta$ [%]		177	229
$P_{rated}$ [kW]		6	7
$Q_{HE}$ [kWh/y]		3003	2292
SCOP [-]		4.43	5.72
$T_{bivalent}$ [°C]		-10	-
Energy class		<b>A++</b>	<b>A++</b>
$\eta$ [%]		160	236
$P_{rated}$ [kW]		6	7
$Q_{HE}$ [kWh/y]		4112	2774
SCOP [-]		4.01	5.90
$T_{bivalent}$ [°C]		-10	-
Energy class		<b>A++</b>	<b>A++</b>
$\eta$ [%]		219	220
$P_{rated}$ [kW]		6	7
$Q_{HE}$ [kWh/y]		1487	1483
SCOP [-]		5.48	5.49
$T_{bivalent}$ [°C]		-	-
CONTROLLER			
			
		+ QAA55/75	class VII    3.5% ↓
		- QAA55/75	class III    1.5% ↓