



**ENERG** Y IJA  
енергия - ενεργεια IE IA

WW 11







55 °C

**A++**

35 °C

**A++**






**43** dB


■ 9    ■ 11

■ **9**    ■ **11**

■ 9    ■ 11

kW    kW






- dB

2015

811/2013

WW 11		ErP Data	
		55 °C	35 °C
Energy class		<b>A++</b>	<b>A++</b>
$\eta$ [%]		180	234
$P_{rated}$ [kW]		9	11
$Q_{HE}$ [kWh/y]		4658	3556
SCOP [-]		4.51	5.85
$T_{bivalent}$ [°C]		-9	-
Energy class		<b>A++</b>	<b>A++</b>
$\eta$ [%]		161	238
$P_{rated}$ [kW]		9	11
$Q_{HE}$ [kWh/y]		6378	4302
SCOP [-]		4.02	5.94
$T_{bivalent}$ [°C]		-9	-
Energy class		<b>A++</b>	<b>A++</b>
$\eta$ [%]		227	228
$P_{rated}$ [kW]		9	11
$Q_{HE}$ [kWh/y]		2305	2299
SCOP [-]		5.68	5.69
$T_{bivalent}$ [°C]		-	-
CONTROLLER			
		+ QAA55/75	class VII    3.5% ↓
		- QAA55/75	class III    1.5% ↓