



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

AW 05 EVI Block



55 °C

35 °C



A++

A++



44 dB



63 dB

■ 5
■ 6
■ 8
kW

■ 5
■ 6
■ 8
kW



2015

811/2013

AW 05 EVI Block

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	131	165
P_{rated} [kW]	6	6
Q_{HE} [kWh/y]	3201	2516
SCOP [-]	3.28	4.12
$T_{bivalent}$ [°C]	-10	-9

	A+	A++
Energy class	A+	A++
η [%]	112	152
P_{rated} [kW]	5	5
Q_{HE} [kWh/y]	4651	3409
SCOP [-]	2.79	3.79
$T_{bivalent}$ [°C]	-10	-9

	A++	A++
Energy class	A++	A++
η [%]	188	188
P_{rated} [kW]	8	8
Q_{HE} [kWh/y]	1350	1348
SCOP [-]	4.69	4.70
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓