



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK AWi 16 EVI




	55 °C	35 °C
Energy class	A++	A++
η [%]	132	163
P_{rated} [kW]	11	10
Q_{HE} [kWh/y]	10273	8331
SCOP [-]	3.31	4.07
$T_{bivalent}$ [°C]	-	-9




	55 °C	35 °C
Energy class	A+	A++
η [%]	105	145
P_{rated} [kW]	14	14
Q_{HE} [kWh/y]	15706	11329
SCOP [-]	2.62	3.62
$T_{bivalent}$ [°C]	-	-9

	55 °C	35 °C
Energy class	A++	A++
η [%]	150	150
P_{rated} [kW]	6	6
Q_{HE} [kWh/y]	5774	5770
SCOP [-]	3.76	3.76
$T_{bivalent}$ [°C]	-	-




50 dB



64 dB

	55 °C	35 °C
14	14	14
11	10	10
6	6	6
kW	kW	kW



2015 811/2013

AWi 16 EVI

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	132	163
P_{rated} [kW]	11	10
Q_{HE} [kWh/y]	10273	8331
SCOP [-]	3.31	4.07
$T_{bivalent}$ [°C]	-	-9

	55 °C	35 °C
Energy class	A+	A++
η [%]	105	145
P_{rated} [kW]	14	14
Q_{HE} [kWh/y]	15706	11329
SCOP [-]	2.62	3.62
$T_{bivalent}$ [°C]	-	-9

	55 °C	35 °C
Energy class	A++	A++
η [%]	150	150
P_{rated} [kW]	6	6
Q_{HE} [kWh/y]	5774	5770
SCOP [-]	3.76	3.76
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓