




**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

AiWa 08i EVI Out



55 °C

35 °C



**A++**

**A++**



- dB



**64** dB

■ 7  
■ **6**  
■ 3  
kW

■ 7  
■ **5**  
■ 3  
kW



2015

811/2013

**AiWa 08i EVI Out**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	134	164
$P_{rated}$ [kW]	6	5
$Q_{HE}$ [kWh/y]	5163	4186
SCOP [-]	3.34	4.09
$T_{bivalent}$ [°C]	-	-10

	A+	A++
Energy class	<b>A+</b>	<b>A++</b>
$\eta$ [%]	106	148
$P_{rated}$ [kW]	7	7
$Q_{HE}$ [kWh/y]	7912	5695
SCOP [-]	2.66	3.69
$T_{bivalent}$ [°C]	-	-10

	A++	A++
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	150	150
$P_{rated}$ [kW]	3	3
$Q_{HE}$ [kWh/y]	2912	2910
SCOP [-]	3.74	3.74
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓