



# ENERG

енергия - ενεργεια

Y IJA

IE IA


BW 17





55 °C

**A++**

35 °C

**A++**








**46 dB**

16  
**16**  
16  
kW

17  
**17**  
17  
kW



2015
811/2013

BW 17		ErP Data	
		55 °C	35 °C
Energy class		<b>A++</b>	<b>A++</b>
$\eta$ [%]		138	184
$P_{rated}$ [kW]		16	17
$Q_{HE}$ [kWh/y]		9928	7406
SCOP [-]		3.45	4.60
$T_{bivalent}$ [°C]		-9	-
Energy class		<b>A+</b>	<b>A++</b>
$\eta$ [%]		120	185
$P_{rated}$ [kW]		16	17
$Q_{HE}$ [kWh/y]		13767	8927
SCOP [-]		3.01	4.63
$T_{bivalent}$ [°C]		-9	-
Energy class		<b>A++</b>	<b>A++</b>
$\eta$ [%]		182	182
$P_{rated}$ [kW]		16	17
$Q_{HE}$ [kWh/y]		4799	4789
SCOP [-]		4.54	4.54
$T_{bivalent}$ [°C]		-	-
CONTROLLER	 	+ QAA55/75    class <b>VII</b> 3.5% ↓ - QAA55/75    class <b>III</b> 1.5% ↓	