

ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK


BWi 16


55 °C

A++

35 °C

A++






46 dB


■ 15 ■ 16

■ **15** ■ **16**

■ 15 ■ 16

kW kW





- dB

2015

811/2013

BWi 16

ErP Data

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 141 | 188 |
| P_{rated} [kW] | 15 | 16 |
| Q_{HE} [kWh/y] | 9343 | 6971 |
| SCOP [-] | 3.52 | 4.70 |
| $T_{bivalent}$ [°C] | -9 | - |

| | A+ | A++ |
|---------------------|-----------|------------|
| Energy class | A+ | A++ |
| η [%] | 123 | 189 |
| P_{rated} [kW] | 15 | 16 |
| Q_{HE} [kWh/y] | 12956 | 8406 |
| SCOP [-] | 3.07 | 4.72 |
| $T_{bivalent}$ [°C] | -9 | - |

| | A++ | A++ |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 185 | 185 |
| P_{rated} [kW] | 15 | 16 |
| Q_{HE} [kWh/y] | 4517 | 4508 |
| SCOP [-] | 4.62 | 4.63 |
| $T_{bivalent}$ [°C] | - | - |

CONTROLLER



| | | |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |