



**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

TBW 66



55 °C

35 °C



**A++**

**A++**



54 dB



- dB

62  
**62**  
62  
kW

66  
**66**  
66  
kW



2015

811/2013

**TBW 66**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	143	191
$P_{rated}$ [kW]	62	66
$Q_{HE}$ [kWh/y]	38179	28488
SCOP [-]	3.57	4.77
$T_{bivalent}$ [°C]	-8	-10

	A+	A++
Energy class	<b>A+</b>	<b>A++</b>
$\eta$ [%]	123	190
$P_{rated}$ [kW]	62	66
$Q_{HE}$ [kWh/y]	52945	34352
SCOP [-]	3.08	4.74
$T_{bivalent}$ [°C]	-8	-10

	A++	A++
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	190	190
$P_{rated}$ [kW]	62	66
$Q_{HE}$ [kWh/y]	18460	18423
SCOP [-]	4.75	4.76
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓